

Check Snoot Fig. 09-680



Description

Typically used on multiple inlet fire department connections to help prevent backflow of water into connected supply lines. Manufactured of cast brass* and available in two finishes. Select polished brass or polished chrome. Breakable caps or a male NST plug or breakable caps should be installed to protect swivels and prevent debris from being accidentally introduced into the water way. UL Listed.

Installation

Installation of the Check Snoot is achieved with readily available jobsite tools. Prior to installation make sure the proper identification sign has been installed on the nipple. Coat male threads liberally with a suitable pipe thread sealant such as Pipefit®. Tighten FDC one full turn past hand tight. Make sure FDC is aligned according to requirements. Mount horizontally (passive clapper). **DO NOT OVER TIGHTEN. OVERTIGHTENING MAY CAUSE SEVERE STRETCHING AND POSSIBLE CRACKING OF THE OF THE FDC BODY.**

Specifications

Material:

ASTM B16 C36000
Cast Brass*

Finish:

Rough Brass
Polished Snoot Available (NST)

Outlet:

3" Male or FNPT

Swivel:

NST	3.0686 x 7 1/2 T
CF	2.9900 x 7 1/2 T
BCT	3.0000 x 8 TP
NYFD	3.0300 x 8 TP
QST	3.0310 x 7 TP
CIN-new	3.0580 x 6 TP
PHX	3.0620 x 6 TP
TEM	3.0750 x 6 TP
CLV	3.0780 x 8 TP
CIN-old	3.0930 x 6 TP
ONT	3.1250 x 5 TP
DET	3.1250 x 7 1/2 T
NovaSco	3.2300 x 5 TP
Dayton	3.2340 x 6 TP
Richmon	3.3120 x 8 TP
Raleigh	3.3400 x 6 TP

Approvals:

UL Listed 300 PSI

* Contains lead. Not for use in water systems intended for human consumption.

 **WARNING: Cancer and Reproductive Harm -**
www.P65Warnings.ca.gov



The information contained herein is produced in good faith and is believed to be reliable but is provided for guidance and information purposes only. FPPI and its agents cannot assume liability or responsibility for results obtained in the use or misuse of its product by persons whose methods and qualifications are outside and beyond our control. It is the user's responsibility to determine the suitability of, methods of use, preparation prior to use, and appropriate installation for all products purchased from FPPI. It is the user's sole responsibility to observe and adapt such precautions as may be advisable or necessary for the protection of personnel and property in the handling and use of any of our products.



PROJECT INFORMATION	APPROVAL STAMP
Project:	Approved
Address:	Approved as noted
Contractor:	Not approved
Engineer:	Remarks:
Submittal Date:	
Notes 1:	
Notes 2:	