



COLUMBIA PLANT

1411 Lancaster Avenue
Columbia, PA 17512-1900
Telephone: 717-684-4400
Fax: 717-684-6868

CERTIFICATE OF COMPLIANCE SERIES 7800 CHECK VALVES

This is to certify that Anvil Figure 78 FP UL/ULC/FM and Figure 78 Commercial Check Valves are assembled and tested by Anvil International in Columbia, PA. These Valves have passed hydrostatic testing at 600 psi. and comply with the following specifications:

Material –

- **Body**
 - Ductile Iron **ASTM A-536, Grade 65-45-12**
 - **Clapper: 2"-5"**
 - Stainless Steel **Type 304**
 - **Clapper: 6"-12"**
 - Ductile Iron **ASTM A-536, Grade 65-45-12**
 - **Clapper Facing**
 - Grade E **EPDM - 7811**
 - Grade T **Nitrile - 7821**
 - **Seat Ring**
 - Stainless Steel **Type 304**
 - **Hinge Pin**
 - Stainless Steel **Type 304 or 302**
 - **Hinge Pin Plugs and Drain Plugs**
 - Gray Cast Iron **ASTM A-126 Class A**
 - **Hinge Pin Bushings**
 - Sintered Bronze **ASTM B-438**
 - **Spring**
 - Stainless Steel **Type 302**
- Pressure Rating**
- **Maximum Rating 300 psi maximum working pressure**

NOTE: Refer to catalog for additional operating information, UL/ULC listing, and FM approval information.

Certified for and on behalf of Anvil International - Columbia Plant.


Frank DeSolis
Quality Manager

February 13, 2017